


TENDER FOR WATERPROOFING TREATMENT FOR UNDERGROUND FIRE WATER STORAGE TANK AT KG ROAD OFFICE COMPLEX	
INVITED BY	TENDER No.:AO1/PREM/24-25/03
State Bank Of India, Engineering Section, <u>Administrative Office -1,Network-I,</u> Ground Floor,Mysore Bank Circle, K G Road, Bengaluru – 560009	DATE: 26.03.2025
Contact Person: Er. Narendran Arun,Ph:7760436124	EMD : ₹4200/- DD drawn in favour of Chief Manager (HR & Admin.),AO-1 Bengaluru South payable at Bengaluru LAST DATE : 11.04.2025 TIME : 3.00 PM

**TENDERS ARE INVITED ONLY FROM BANK EMPANELLED CIVIL CONTRACTORS UNDER A1 CATEGORY (UPTO Rs.10LAKHS).**

**THE BIDDERS MAY SUBMIT THEIR TENDERS AS PER THE FOLLOWING FORMAT TO ABOVE ADDRESS, DULY SIGNED IN ALL PAGES ALONG WITH PRICE BID.**

**TERMS AND CONDITIONS**

- 1) All the required materials, tools and tackles, scaffolding etc. shall be in your scope.
- 2) The contractor should have visited the site and examined site conditions before quoting.
- 3) In the event of an order, you shall complete the work within **30 days** of receipt of work order/handing over.
- 4) The Bank reserves the right to accept or reject any quotation or all other quotations without assigning any reason.
- 5) TDS and statutory deductions as applicable will be deducted from bill amount.
- 6) **Payment terms**
  - 90 % on completion of work.
  - balance 10 % on completion of defect liability period of 1 year.
- 7) If the Work is not completed in the specified time the contractor will be levied liquidated damages @ 1/2 % per week subject to a maximum of 5 % of the contract amount.
- 8) The contractor is required to comply with all acts of Govt. relating to labour and the rules and regulations made there under from time to time and submit at the proper times all particulars and statements required to be furnished to the labour authorities.
- 9) In carrying out the work, the contractor shall comply with the provisions of the safety code.

Thanking you,  
Yours faithfully,

DEPUTY GENERAL MANAGER (B&O),  
AO-1 BENGALURU SOUTH.

#### Materials to be Used – Recommended Brands

Material	Brand 1	Brand 2	Brand 3	Purpose
Bonding Agent	Fosroc Nitobond SBR	Dr. Fixit Pidi-crete URP	Sika Latex Power	Improves adhesion for repair layers
Repair Mortar (for Sealing Grout Holes)	Fosroc Renderoc RG	Dr. Fixit Micro Concrete	SikaRep Micro-crete-4	Seals injection points and repairs honeycombing
Grout Admixture (Non-Shrink Additive)	Fosroc Cebex 100	Dr. Fixit Pidi-crete MPB	Sika Intraplast N200	Enhances grout flow and reduces shrinkage
Cementitious Waterproofing Slurry	Fosroc Brushbond / Nitocote CM210	Dr. Fixit Pidifin 2K	SikaTop Seal 107	Waterproof coating for sump walls
Microfine Cement for Pressure Grouting	Ultratech Microfine Cement	Dura Microfine Cement	Ambuja Micro-fine Cement	Used in injection grouting to fill voids

---

#### General Notes on Material Selection:

1. **All materials should be sourced from authorized dealers** to ensure authenticity.
2. The contractor **must provide compliance certificates** from the manufacturer.
3. **Mixing ratios and application methods** should follow the manufacturer's technical datasheets.
4. **Alternative brands may be considered** only if they meet the required specifications.