



TENDER ID-AO-AUG/0520211101



**STATE BANK OF INDIA
ADMINISTRATIVE OFFICE, AURANGABAD**

INVITES

UNIT ITEM RATE TENDERS (PHYSICAL FORM)

FROM

**EMPANELLED ELECTRICAL CONTRACTORS
WITH SBI LHO MAHARASHTRA**

**FOR
ELECTRICAL WORKS**

FOR

ADB BRANCH DONGARKADA (05928)

LAST DATE & TIME for

Submission of tender:

: At 15:00 Hrs on 15-11-2021

Opening of tender

: At 15:30 hrs on 15-11-2021



STATE BANK OF INDIA
RBO, JALNA
NOTICE INVITING TENDER

SBI, invites unit item rate sealed tenders (physical form) for **ELECTRICAL & DATA CABLING** works for ambience improvement work of our **ADB BRANCH DONGARKADA (05928)**, from empanelled Electrical contractors of appropriate category with SBI, LHO MAHARASHTRA.

WORK	EMPANELLED CATEGORY	EMD
1. ELECTRICAL	Electrical contractors of up to & above Rs.10 Lacs	Rs.7100/-

1.	EMD	In the form of DD drawn in favour of STATE BANK OF INDIA, Administrative office, Aurangabad
2.	Time allowed for completion of each work	45 days
3.	Validity of tenders	3 months
4.	Liquidated damages	0.5% per week subject to maximum of 5% of the value of the work.
5.	Defect liability period	12 months
6.	Address at which the tenders are to be submitted	The Asst. General Manager, State Bank of India, Regional Business Office (Jalna), Administrative Office N-5, CIDCO, Aurangabad-431003 On or Before 15:00 hrs.15-11-2021
7.	Date and Venue of tender opening	The Asst. General Manager, State Bank of India, Regional Business Office (Jalna), Administrative Office N-5, CIDCO, Aurangabad-431003
8.	For any technical query contact	Bank's engineer: 9373536836

- Tender Document is not found as prescribed, the tender shall be rejected.
- In case the date of opening of tenders is declared as a holiday, the tenders will be opened on the next working day at the same time.
- SBI has the right to accept/ reject any or all tenders without assigning

DY.GENERAL MANAGER,
SBI, ADMINISTRATIVE OFFICE, AURANGABAD



TENDER FOR ELECTRICAL WORKS FOR ADB BRANCH DONGARKADA (05928)

TERMS & CONDITIONS:

1. The rates quoted in the tender should be **exclusive of GST** but inclusive of all over heads. All the rates are to be written both in figures and words.
2. Tenders submitted **without EMD** in the prescribed form or incomplete tenders and delayed tenders are liable to be rejected.
3. The time allowed for completion of the work to the satisfaction of the Bank is **90 days**.
4. The tenderers should visit and inspect the site before quoting the rates in the tender.
5. The work should be carried out without causing any inconvenience to the staff & customers.
6. The work should be completed in all respects as per the specification to the satisfaction of the Bank within the stipulated time. Time is the essence of the contract and liquidated damages @ 0.5% per week subject to a maximum of 5% of contract value will be deducted in case of any delay in execution of the work.
7. The quantities given in the Bill of Quantities are only tentative and the same may be increased, decreased or deleted at the discretion of the Bank. Payment will be effected only for the actual quantity of work carried out after verification of the work at site by the Bank's Engineer. No part payment will be made during execution of work.
8. Security Deposit@ 5% of the bill amount will be retained by the Bank and refunded only after the defect liability period of one year is over and no defects noticed in the works.
9. The successful Contactor should take 'Contractor's All Risk' policy for the full amount of contract value, for duration of 6 months, immediately after starting the work.
10. The Contractors are expected to strictly adhere to the labour laws in force from time to time by both the central and State Governments. The necessary records should be maintained at site and all amenities to the labourers has to be made available at site as per law. The labour license shall also to be obtained from the authorities concerned.
11. The Contractors are advised to read the specifications carefully and any clarifications regarding specifications / sketch can be had from the Bank's Civil & Electrical Engineers at Administrative Office, NAGPUR.
12. The works should be carried out in accordance with the drawings, specifications, etc., of the Bank and the contract shall be governed by the Bank's rules, regulations, contractual terms and standard general & special conditions of contract as amended by the Bank from time to time. In the event of Bank suffering any loss due to the default on the part of the contractor in carrying out the work within the time limit and as per specifications, the contractor shall be liable to compensate the Bank.
13. The Bank reserves the right to accept or reject any tender in whole or part without assigning any reasons hereof.

14. Unsafe Wiring or Equipment

- a) All materials to be used should be of the best quality and as per specifications.



b) Pursuant to the Electricity Safety Regulations, Electrical Contractors/ Workers are not permitted to allow unsafe wiring or equipment to be connected or remain connected to an electrical installation or supply of electricity. Accordingly, if during the course of carrying out work at your property we encounter faulty or unsafe wiring or equipment, we are legally obliged to repair or isolate the same without additional cost, and, report the matter to circle office recommending for black listing.

15. Materials, Details and Dimensions

a) The client before accepting this quotation acknowledges that adequate care has been taken to ensure that the materials and articles specified are of the correct type, size, rating, standard, quality, colour, finish and express the full requirements and conform to the specification and drawings against which the quotation was submitted. **No PAYMENT WILL BE MADE IF THE MATERIAL FOUND NON STANARAD OR NON SPECIFIED IN BOQ.**

b) Local liaison with Electricity Board for enhancement of electrical load of the Branch will be in the scope of lowest bidder.

16. The work will be inspected and joint measurement taken by the Bank's Engineer before making the payment.
17. The rates to be quoted shall be fixed and inclusive of all charges, taxes, transportation, loading-unloading etc. No additional payment will be made towards these on any account.
18. The contractors are requested to inspect the area in question before quoting the rates.
19. The tender should be valid for 3 month.
20. The contractor should take proper care of the Bank's furniture, fixtures, fittings records, stationery, etc. while carrying out the above works. Any damage caused directly and indirectly by the contractor will have to be compensated.
21. The contractor shall make his own arrangement for procuring all the materials required for execution of the above work and may store the same at site at his own risk and cost.
22. **Payment Terms:** Advance against materials will not be paid. The Contractor shall not submit interim bills when the approximate value of work done by him is less than Rs. 3.0Lakhs. Our payment terms shall be 75% subject to delivery of material with eight percent completion of site work and verification of our site by Bank's Engineer. 20% payment shall be released on hundred percentage of completion of site and the report duly attested by Branch Manager bearing name, designation and branch seal. 5% balance of the cost will be released after the defect liability period of 1 year from the date of submission of final bill or against suitable bank guarantee (at the discretion of the Bank) for an equal amount involved, from any nationalized bank other than State Bank Of India and valid for defect liability period. Warranty shall be applicable to entire set of by the vendor.
23. The retention amount shall not carry any interest.
24. The contractor should acquaint himself with the site conditions, local traffic regulations, local authority regulations, labour tax rules etc., and quote the rates accordingly. No extra charges/increase in the rates shall be considered on any account.
25. The contractor or his employees shall work diligently with utmost safety and as per safety norms. In case of any injury, accident, damage or death caused to the contractor or any of his agents or employees, the Bank shall not be liable for any such liability.
26. All pages should be signed by the proper tier/partner/director of the firm/ contractor with official seal i.e. the Technical Bid and Price bid incase if it found that the papers are not signed the tender is summarily rejected



27. The above conditions are accepted and we agree to carry out the work as per Bank's specifications and drawings.

Place:

Date:

Signature of the Contractor with Seal

TENDER FOR ELECTRICAL WORKS FOR ADB BRANCH DONGARKADA (05928)

(THE MAKE LISTED BELOW SHOULD BE FIRST APPROVED BY THE BANK BEFORE USE IN CONSTRUCTION)

LIST OF MATERIALS OF APPROVED BRAND AND THEIR MANUFACTURERS

LIST OF APPROVED MANUFACTURERS FOR LT ELECTRICAL WORKS		
S.NO.	MATERIALS	APPROVED MANUFACTURERS
1	Moulded Case Circuit Breaker (MCCB)	L & T, Legrand, Schneider, Hager Siemens,Havells
2	Switch Fuse Unit (SFU)	L & T, Siemens, ABB, Siemens
3	Power Contactors	L & T, Siemens, Schneider
4	Meters	HPL, L & T, IMP
5	Armoured LT cable	Polycab, Havells, Finolex, R R Kabel
6	Cable Termination	Dowells, Comet, Frontier Technologies
7	Cable Tray	Profab, Metalemms, Asian Ancillary Corporation
8	PVC Conduit & Accessories	Precision , Vraj
9	Wires (FRLS only)	RR Kabels, Havells, Finolex, Polycab
10	Modular Switches & Sockets with PVC Box	MK-(wrap round), Roma, Schneider - (Opale model), Cartree (havells)- (Verona model), L&T -(Oris model
11	Distribution Board, MCB, RCCB & RCBO	Legrand, Schneider ,Hager, L&T, Siemens

12	Data/ Voice Cable & accessories	i)D-link, HCL/RR Kabels, Finolex
13	Light Fixtures	Wipro ,CGL, Philips, Orient, Bajaj
14	Tubes, PL's & CFL's	Wipro Philips, Osram
15	Ceiling Fan	CG, Havells, Bajaj, Orient,USHA
16	Exhaust Fan	CG, Almonard, Alstom
17	Speakers	BOSCH, Ahuja, Philips
18	Amplifier	BOSCH ,Ahuja, Philips
19	Electrical LT Panel	ERDA/CPRI & ISO 9001:2008 Approved Panel Manufacturer Only
20	Capacitors	Siemens, L& T, GE,ABB, Universal
21	CT'S / PT'S	AE, Kappa, Ricco, Rishabh
22	APFC Relay.	HPL, Emercon, Alstom, Beluk, L & T
23	Contactor / Timer	i) Schneider ii) Hager iii) L & T iv) Siemens iv) Legrand
24	Energy Meters	HPL, Schneider, L & T, Tecnic, AE,HPL
25	Data / Voice cabel & Accessories	D- Link , AMP
NOTE:-	1.All approved materials samples shall be approved from the Bank's Engineer	
	2.SBI reserves final right to select any make for any item from the above mentioned list of make.	
	3.SBI reserves final right to reject any material if found out of approved list of make/not up to the acceptable standards	
Important: Please Tick (/) the make of materials considered in the Tender.		