

**STATE BANK OF INDIA  
LOCAL HEAD OFFICE, GUWAHATI  
PREMISES & ESTATE DEPARTMENT  
GUWAHATI, ASSAM.**

**ELECTRICAL INSTALLATION WORK FOR RENOVATION OF KAMPUR BRANCH, ASSAM**

**PRICE BID**

Sl.No.	Description	UOM	Qty.	Rate (Rs.) (Exclusive of GST)	Amount (Rs.) (Exclusive of GST)
1	Main Panel :- Supplying, Installing, testing and commissioning of fabricated floor mounted cubicle type distribution Panel Board suitable for 415 V comprising of suitable copper bus bars, 125A 4P MCCB with overvoltage protection as incoming and 3 Nos. of 63A 4P MCCB at outgoing in compartmentalized chamber fully isolated with 2 mm thick steel sheet and 3 mm steel channel painted with 2 coats of red oxide primer paint followed by finishing paint with interconnection etc. as required.(MCCB Make - Legrands/Havells/L&T/SIEMENS/schnieder)	Set	1		
2	Sub-main line:- Wiring in MS conduit of IS specification of Proper size with core PVC insulated stranded copper wire 11KV grade (Finolex/Havells/Polycab/RR Kabel/KEI/gloster) and with supply ,installation, commissioning of all the materials required including proper termination, connection in complete as required from main DB to various DBs:-				
	i) with 3nos 4sq.mm (1ECC)	RM	140		
	ii) with 3nos 6sq.mm (1ECC)	RM	110		
3	Supply ,installation ,testing and commissioning of distribution board manufactures made sheet steel enclosure With the following MCBs				
	i) Computer/Raw power DB, 8way SPN double door with 40A (30mA)DP RCCB as incomer & 6nos 10A SP MCB as outgoing.	No.s	2		
	ii) DB with 40A DP MCB.	No.s	2		
	iii) DB with 63A DP MCB.	No.s	2		
	iv) DB with 16A DP MCB.	No.s	2		
	v) DB with 32 A DP RCCB, 30mA for AC	No.s	5		
	vi) 4 way VTPN Double Door Distribution Board with 63A 4 Pole MCCB ( 36kA) as incomer and 12Nos. 32A SP MCB's at outgoing	Set	1		
	vii) 4 way VTPN Double Door Distribution Board with 63A 4 Pole MCCB ( 36kA) as incomer and 2 No. of 40A SP MCB , 6 nos. of 32 A SP MCB, 4 nos of 16A SP MCB at outgoing	Set	1		
	viii) Light DB 8way SPN double door with 32A (30mA)DP RCCB as incomer & 6nos 10A SP MCB as outgoing.	No.s	2		

**GUWAHATI, ASSAM.**

4	Supplying, installing and commissioning of PVC Armored cable complete with proper cable glands and two nos. of 8SWG GI wire (Havell's/RR kebel/KEI/gloster) alongwith all the other materials required including proper connection in complete as required from main Panel, Power Distribution Board to various DBs .			
i)	With 3.5 core x 25 sq. mm cable	RM	80	
ii)	With 3.5 core x 50 sq. mm cable	RM	40	
5	Supply, installing and commissioning of earth station including digging and refilling back the pit with black soil and with 3.15mm x300mm size copper plate duly tinned through out the surface of the plate, placed at least 3.0 Mtr,below the ground level with 2nos 10sq.mm PVC insulated stranded copper conductor in 20mm GI pipe, fixed to the plate and providing 40mm,3.1 mtr,long GI pipe with reducer and funnel at top for watering pipe with supplying and laying earth continuity wire of 2x10sq.mm copper stranded PVC green color in heavy duty MS conduit on the wall from earth plate to starting point of the line earth connector.	Set	4	
6	Computer/Raw Power point wiring in MS conduit of IS specification of proper size with 3nos 2.5sq.mm single core PVC insulated stranded			
i)	With 3nos 6A socket with single 16A switch.	No.s	24	
ii)	With 2nos 16A socket with individual switch.	No.s	12	
iii)	With 1nos 16A socket with individual switch.	No.s	10	
7	Supply & Fixing of 15Watt commercial down lights of system efficacy >100lm/W. The light should be recessed mounted slim circular type LED panel with die-cast aluminium housing and smooth powder coated finish with anti glare UV stabilized diffuser and separate energy efficient electronic driver having inbuilt surge protection upto 2.5kv. Make :- Bajaj/Havels/Phillips/Wipro/Crompton	Nos	40	
8	Supply and fixing of 2'x2' LED commercial Luminaire of 36 Watt with system efficacy of 110lm/W. The light should be recessed mounted type and low depth with CRCA powder coated housing, high transmittance diffuser for symmetric light distribution with non-integral energy efficient isolated electronic driver and inbuilt surge protection upto 3kv. Make :- Bajaj/Havels/Phillips/Wipro/Crompton	Nos	22	
9	Supply installation testing and commissioning of LED batten Single Tube light fittings with 20W with glare free light distribution wall mounted at ceiling/false ceiling level/. Make :- Bajaj/Havels/Phillips/Wipro/Crompton	Nos	30	
10	Supply and installation of Wall Mounted fan 400 /450 mm Metallic body and metallic Blade ,1400 rpm Havels FHWV3TFSLB18 or equivalent of crompton/bajaj/usha/orient make	No.s	14	
11	Supply and installation of 5 Star rated Ceiling fan 1200 mm crompton/bajaj/usha/havell's make	No.s	4	
12	Supply and installation of Heavy Duty metallic body & Blades Exhaust Fan 225/300 mm crompton/bajaj/usha/havell's make	No.s	4	

**GUWAHATI, ASSAM.**

13	Supplying, installation, testing & commissioning of Security light with 25W LED lamps with pressure die cast housing with epoxy coated dark graphite grey colour finish and prismatic polycarbonates cover with individual LED lenses, including necessary GI bracket with clamp. Make :- Bajaj/Havels/Phillips/Wipro/Crompton	Nos.	4		
14	Wiring for light/fan/exhaust fan points using 3 X 1.5 1.1 kV grade PVC insulated stranded copper conductor wire(Finolex/Havell's/Gloster/RR kebel/KEI) for phase, neutral and earth in 25 mm dia heavy duty MS conduit along with associated accessories like MS junction boxes, bends, saddles, screws et. concealed in wall, floor, under flooring, below false ceiling or on surface as well as suspended from ceiling with 25mm X 3 mm MS flat suspenders duly painted above false ceiling from individual light/Fan/Exhaust Fan point outlet. etc. to individual modular type switch boards, 10 Amp modular plate type switches etc.(MK/Legrand's/Havel's /anchor/Crabtree/Northwest), as required complete including circuit wiring with 3 X 2.5 sqmm. 1.1 kV grade PVC insulated stranded copper conductor wire and as per site requirement and as instructed by Engineer.				
i)	one light/fan controlled by one switch	No.s	115		
ii)	6A socket & switch at same board	No.s	7		
iii)	Fan Point with electronic modular type regulator.	No.s	4		
	<b>GST on work contract will be extra as applicable.</b>	<b>Total</b>			